

## Fixed Ladder Inspection

Department: \_\_\_\_\_ Building \_\_\_\_\_

Location of the ladder: \_\_\_\_\_

Ladder description/identification \_\_\_\_\_ Ladder length (ft.) \_\_\_\_\_

Inspector (Competent Person) \_\_\_\_\_ Date: \_\_\_\_\_

Note: This does not apply to portable ladders or step bolts on telecommunication towers or fixed ladder rungs in elevator shafts.

General		N/A	Yes	No
1	The rungs are uniformly spaced 10-14 in. apart (6.5-12 in. for ship stairs) parallel, and uniform in size.			
2	The rungs/cleats are at least 16 in. wide (at least 18 in. wide and 4 in. deep for ship stairs)			
3	The clearance between the steps/rungs/grab bars and structure is at least 7 in.			
4	The grab bars are not protruding on the climbing side beyond the rungs of the ladder.			
5	The ladder is in good working condition (i.e., no loose rungs/steps/side rails, cracks, corrosion).			
6	The rungs are free of excess dirt/grease/oil/slippery material.			